



DIVISION OF  
PROCUREMENT

**GOVERNMENT OF  
THE UNITED STATES VIRGIN ISLANDS**

~~~~~

**DEPARTMENT OF PROPERTY & PROCUREMENT**

8201 SUB BASE, 3<sup>RD</sup> FLOOR  
ST. THOMAS, U. S. VIRGIN ISLANDS 00802



STT: TEL.: (340) 774-0828  
FAX: (340) 777-9587

August 10, 2018

**AMENDMENT #2 – IFB021DPWT18 (C) Clearview Apartments/Route 33  
Emergency Road Repairs - ER-VI-33(7) in Thomas, Virgin Islands**

**INSERT: Questions and Answers**

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS AMENDMENT WITH THEIR BID  
PROPOSAL.

## **Questions and Answers:**

**Question 1: Does the Preferred Bidders Act apply to this project?**

**Response:** No. The Preferred Bidders Act does not apply.

**Question 2: Can an Irrevocable Letter of Credit be used in lieu of Payment and Performance Bonds?**

**Response:** No.

**Question 3: Is there access for equipment provided for through the bottom of the site at the apartment complex?**

**Response:** Yes, the contractor may access the existing right of way and temporary construction easement through the Clearview Apartments parking lot. The contractor shall coordinate the movement of vehicles and equipment through the parking area with DPW and Clearview Apartments owner's representative. The contractor shall be responsible to repair any damages related their construction activities to the parking area and surrounding areas, at the contractors cost. Staging, parking, and other construction activities shall be limited to the right of way and temporary construction easement.

**Question 4: Please confirm Viya's standards for the conduit. Should it be schedule 80 PVC?**

**Response:** Contractor shall install schedule 80 PVC with detectable warning tape in accordance with the Cable System Installation drawings and details provided in Addendum 1.

**Question 5: Please advise where to relocate the mailboxes.**

**Response:** The exact location is to be determined. The mailbox shall be relocated by the contractor to a temporary location on route 33 or Scott Free Rd, within the project limits, and moved back to the original location after the proposed work is completed. Coordinate location with DPW. The relocation of the mailbox shall not be measured for payment.