



Department of Property & Procurement

Government of the United States Virgin Islands

3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820

8201 SUB BASE, 3RD FLOOR, ST. THOMAS, U. S. VIRGIN ISLANDS 00802

ST. CROIX MAIN OFFICE: 340.773.1561 | ST. THOMAS MAIN OFFICE: 340.774.0828

ST. CROIX FAX: 340.773.0986 | ST. THOMAS FAX: 340.774.9587

HTTP://DPP.VI.GOV



July 28, 2021

AMENDMENT TWO (2) IFB060SPRC21(C)— Cramer's Park Pavilions Hurricane Repair Project, St. Croix, U.S. Virgin Islands

INSERT QUESTIONS AND ANSWERS

Q1 On drawing A4.02, detail 2 indicates that the posts are to be 6 5/8" O.D., is that the correct size? The top and bottom rails are indicated to only be 1 5/8" O.D.

A1 The posts are to be 2 7/8" O.D.

Q2 On sheet AS1.02, a note states "remove and replace security light and mounting arm, typical at 9 locations." Did not see any detail or specification in the electric prints. Please provide.

A2 The security lights and mounting arms are WAPA equipment. The removal and replacement of these items will need to be coordinated with WAPA by the contractor at the beginning of the project.

Q3 On walk-through, it was noticed that these lights were being fed directly from WAPA. Please confirm that these lights will be fed directly from WAPA lines, and they are included in this project.

A3 The security lights are fed directly from WAPA. The removal and replacement of these items will need to be coordinated with WAPA by the contractor at the beginning of the project.

Q4 The drawings specify 6" half round gutters. This type of gutter is the most expensive and the most vulnerable in storms. Please confirm that K Style gutters can be used.

A Please provide a cost for 6" half round gutters as specified on the bid sheet.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

BIDDERS MUST ACKNOWLEDGE RECEIPT OF THIS AMENDMENT WITH THEIR BID PROPOSAL.