


## **Department of Property&Procurement**

## Government of the United States Virgin Islands



HTTP://DPP.VI.GOV



## **February 7, 2022**

## **AMENDMENT THREE (3)**

IFB022OAGC22(C)-Repair/Replace Walkway, Roadway, and Exterior Lights at the Bethlehem Military Compound, St. Croix, USVI

**INSERT: Question and Answers** 

Question: Please provide specs for light fixtures that you want replaced. Wall mount, sign lights, pole lights bollard lights. Watts of light fixtures.

Answer: The specifications attached are for information purposes only. The wall mounted fixtures should be Hubbell Laredo LMC Series, Gardco 111MT or 141 Series or similar fixtures. The pole fixtures shall be Wide lite Optra OPP-250 Series or similar. The bollards are Vonda VBN-36. The light fixtures are to be LED and provide a minimum 3.8-foot candles of light at 25' of height.

Question: Please provide specs on batteries and cabinet replacements for lights.

Answer: There are no specifications available for the batteries and cabinets. Batteries must be sufficiently sized to provide for dusk to dawn operation of the lights.

Question: On scope it states to trouble shoot electrical pole lights and the bollard light fixtures.

We will quote to troubleshoot and provide a report on the problem and then provide a price to fix in a change order. Will this work? Answer: The intent of this line item is to ensure that there is steady power for a completed project. In replacing the light fixtures, the contractor is to ensure that the light fixtures are fully functional.

Question: Does this project qualify for a Proffered Bidder?

Answer: No, this project does not qualify for preferred bidder status.

Please Note: The miscellaneous electrical work is to cover any unforeseen damages that may exist in the electrical conductors.

All other terms and conditions remain the same.

A copy of this amendment must be returned with your bid.