



Department of Property & Procurement

Government of the United States Virgin Islands

3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820

8201 SUB BASE, SUITE 4, ST. THOMAS, U. S. VIRGIN ISLANDS 00802

ST. CROIX MAIN OFFICE: 340.773.1561 | ST. THOMAS MAIN OFFICE: 340.774.0828

ST. CROIX FAX: 340.773.0986 | ST. THOMAS FAX: 340.777.9587

[HTTP://DPP.VI.GOV](http://DPP.VI.GOV)



AMENDMENT ONE (1)

March 16, 2016

TO:

**SUBJECT: IFB009SPRC17 (C) Construction of the
Recreational Center in the Community of Estate
Barron Spot, Christiansted, St. Croix.**

INSERT: Question & Answer

**Q. What percent of this project is structural steel vs
masonry work?**

**A. It must be emphasized that the proposed
Recreational center that will be constructed at
Barron spot is not a steel building. It is a masonry
Building that is structurally supported by No.4 &
5 rebar. Therefore zero steel columns and beams
will be utilized for the project.**

All other terms and conditions remain the same.

A copy of this amendment must be returned with your bid.