



# Department of Property & Procurement

Government of the United States Virgin Islands

3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820

8201 SUB BASE, SUITE 4, ST. THOMAS, U. S. VIRGIN ISLANDS 00802

ST. CROIX MAIN OFFICE: 340.773.1561 | ST. THOMAS MAIN OFFICE: 340.774.0828

ST. CROIX FAX: 340.773.0986 | ST. THOMAS FAX: 340.777.9587

[HTTP://DPP.VI.GOV](http://DPP.VI.GOV)



## AMENDMENT ONE (1)

March 15, 2018

TO:

---

---

**SUBJECT: IFB014DPWC18 (C) VITRAN Maintenance & Operations Facility in Estate Anna's Hope, St. Croix.**

**INSERT: Questions & Answers**

**QUESTION:** Is the asphalt thickness of 1" and ½" for exterior Driveway and parking lot surfaces adequate where transit buses And heavy equipment will easily wear on the surface integrity Over a short period of time?

**ANSWER: Concrete pavement thickness** – Concrete pavement For vehicles where indicated shall be the same throughout the Project, which is indicated on Sheet S1 as: 6", 4000 psi concrete With 6"x 6"x W2.1x W2.1 WWF on 10ml vapor barrier

**Asphalt thickness** – The bidder's reference to 1" and ½" Dimensions were the maximum size of aggregate not the course Thickness. The course thicknesses are specified as: Base Course 2½" Surface Course 1 ½"

**All other terms and conditions remain the same.**

**A copy of this amendment must be returned with your bid.**