



# Department of Property & Procurement

Government of the United States Virgin Islands

3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820

8201 SUB BASE, 3RD FLOOR, ST. THOMAS, U. S. VIRGIN ISLANDS 00802

ST. CROIX MAIN OFFICE: 340.773.1561 | ST. THOMAS MAIN OFFICE: 340.774.0828

ST. CROIX FAX: 340.773.0986 | ST. THOMAS FAX: 340.774.9587

[HTTP://DPP.VI.GOV](http://DPP.VI.GOV)



November 6, 2019

## AMENDMENT FOUR (4)

IFB005DPWC20 (C)- Repairs to the Frederiksted Cemetery Wall, St. Croix,

USVI.

INSERT: QUESTIONS AND ANSWERS

QUESTION # 1: Since this is a historical wall, is it a requirement from Historical Preservation Commission to match it, including columns?

**Answer: No. The wall will be poured with concrete, it's currently a rubble wall constructed with clay stones. We will not be able to match with existing.**

**All other terms and conditions remain the same.**

**A copy of this amendment must be returned with your bid.**