



Department of Property & Procurement

Government of the United States Virgin Islands

3274 ESTATE RICHMOND, CHRISTIANSTED, U. S. VIRGIN ISLANDS 00820

8201 SUB BASE, 3RD FLOOR, ST. THOMAS, U. S. VIRGIN ISLANDS 00802

ST. CROIX MAIN OFFICE: 340.773.1561 | ST. THOMAS MAIN OFFICE: 340.774.0828

ST. CROIX FAX: 340.773.0986 | ST. THOMAS FAX: 340.774.9587

[HTTP://DPP.VI.GOV](http://DPP.VI.GOV)



March 2, 2020

AMENDMENT FOUR (4)

IFB024DOEC20 (C)- Construction and/or Repairs at Pearl B. Larsen K-8 School, Arthur A. Richards K-8 School and John H. Woodson Jr. High School, St. Croix, USVI

INSERT: QUESTIONS AND ANSWERS

Q. Can VIDE provide utility as built plans for facilities?

A. VIDE does not have as built plans other than those provided in the bid package for the facilities showing the actual utility locations. Bidders are required to visit the sites and identify the closest required utility connection point to the respective modular installation location.

Q. Will repairs to the office modular be required after joining sections?

A. Bidders modular installation cost shall include all flashing and mating of office sections for the Fixed Asset and Information Technology modular offices to ensure a complete and watertight installation.

Q. Will skirting be required at the base of the installed modular.?

A. Yes, skirting will be required at the base of the installed modular.

All other terms and conditions remain the same.

A copy of this amendment must be returned with your bid.